



OFFICE OF PROCUREMENT SERVICES
315 WEST MAIN STREET, SUITE 441
PO BOX 7800
TAVARES FL 32778-7800

PHONE: (352) 343-9839
FAX: 352) 343-9473

ADDENDUM NO. ONE

Date: September 8, 2015

ITB 16-0603

Annual Fire Hose Testing and Ground Ladder Testing

It is the vendor's responsibility to ensure their receipt of all addenda, and to clearly acknowledge all addenda within their initial proposal response. Acknowledgement may be confirmed either by inclusion of a signed copy of this addendum with the initial proposal response, or by completion and return of the addendum acknowledgement section of the solicitation. Failure to acknowledge each addendum may prevent the proposal from being considered for award.

This addendum **does not** change the date for receipt of proposals.

Questions regarding this solicitation were due September 7, 2015. The purpose of this addendum is to address questions received.

Question 1: I reviewed this bid request and it is not common for Fire Protection companies to offer Ladder Inspections. Is it possible for me to only bid on the Fire Hose Inspections?

Answer 1: No, splitting the testing (hose to one company and ladders to another) would cause additional costs to the County. The Department wants the vendor to perform both the hose testing and the ladder testing.

Question 2: In the invitation to bid, you would like to have your hose tested following the NFPA 1962 (2008) standard. The actual standard is NFPA 1962 of 2013. Please verify what version the bid shall follow.

Answer 2: We are not requiring the nozzle/appliance testing but do require testing at new pressures as outlined in the newer standard.

I have received and reviewed this Addendum:

Firm Name: _____ Date: _____

Signature: _____ Title: _____

Typed/Printed Name: _____